

**Walmag Magnetics s.r.o.**

Hulínská 1799/1

767 01 Kroměříž

Czech republic

## LV switchgear test report, quality and completeness certificate

<b>Test Type</b>	partial type ČSN EN 61439- 3 ed. 2		
<b>Serial number</b>		<b>Power grid</b>	3/PEN TN-C-S
<b>Functional designation</b>		<b>Rated voltage</b>	3x230V /400V 50Hz
<b>Protection</b>	IP 54	<b>Rated current</b>	40A
<b>Type of protection</b>	Grounding and wiring		
<b>Checks, measurements and tests:</b> <ul style="list-style-type: none"> <li>- Inspection of the switchboard, inspection of the wiring, protective measures and integrity of the protective circuits: <b>COMPLIES</b></li> <li>- Integrity of protection circuits: <b>COMPLIES</b></li> <li>- Functional test: <b>COMPLIES</b></li> <li>- Measuring of the insulation state: <b>1500V ± 60V AC</b></li> <li>- Insulation test: <b>3M0hm</b></li> <li>- Resistance of non-live parts and PE: <b>COMPLIES</b></li> </ul>			
<b>Overall test result:</b>		<b>Complies without faults</b>	
<p>The product is complete to the extent specified in the custom accompanying documentation. The product must be inspected within the deadlines set by ČSN 3315 00</p> <p>Note: The warranty period is 24 months and is calculated from the date of sale of the product.</p>			
<b>Date:</b>		<b>ÚŘJ confirmation:</b>	